



Riverside County Fire Department
Office of the Fire Marshal
City of Norco
3902 Hillside Ave. Norco, CA 92860
Bus (951) 737-8097 FAX (951) 734-8531



CONCESSION STANDS

1. A fire extinguisher with a minimum rating of 2A10BC, with a California State Fire Marshal approved service tag that reflects a **current inspection date** (within the last 12 months), is required within 75 feet travel of each concession using any type of open flame device.
2. Cooking that requires the use of a deep fat fryer shall have access to a Class K portable fire extinguisher within 30 feet travel distance. Class K extinguishers shall be at least 1.5 gallons capacity.
5. Concession operators using oils for cooking shall have available a noncombustible lid of sufficient size to cover the cooking well completely.
6. All cooking devices shall be in good working condition and be placed on a flat, stable surface.
7. All cooking equipment is restricted to UL approved cooking appliances only.
8. Electrical equipment and cords shall be listed for outdoor use.
3. Multi-plug connections, damaged extension cords, or cords with less than 12-gage wiring are prohibited.
4. All L.P.G. tanks (empty or full) shall be secured with a small chain or other approved device and kept a safe distance from open flame. L.P.G. tanks can be placed into plastic crates for protection.
9. Gasoline for portable generators is not allowed to be stored at the concession stand.
10. Concession stands that do not meet these requirements will not be allowed to participate in the event.

TENTS

1. Tents shall have a flame-resistance label affixed to each separate piece of fabric. The label shall either have the California State Fire Marshal seal of approval or CPAI-84. (see samples below)
2. A tent without a flame-resistance label cannot be used at the event.
3. 2A-10BC rated portable fire extinguishers shall be available within 75-foot travel distance of all tents.



24 pt. type
WARNING
16 pt. type
**KEEP ALL FLAME
AND HEAT SOURCES
AWAY FROM THIS
TENT FABRIC**
12 pt. type
*This tent is made with flame-resis-
tant fabric which meets CPAI-84
specifications. It is not fire proof.
The fabric will burn if left in con-
tinuous contact with any flame
source.*
*The application of any foreign sub-
stance to the tent fabric may render
the flame resistant properties
ineffective.*